



Back Flow Prevention Device (Dual Check Valve)

May 1, 2007

In accordance with applicable Local or State regulations, J&A USA, Inc., the manufacturer of the pedicure whirlpool spa certifies that the following models are equipped with factory installed Dual Check Valve Back Flow Preventor:

- ▶ Cleo
- ▶ Episode Series
- ▶ Pacific Series
- ▶ Petra Series
- ▶ Toepia Series

The specification of the installed device is as follows:

DEVICE NAME	DUAL CHECK VALVE BACKFLOW PREVENTOR
DEVICE MANUFACTURER	WATTS REGULATOR COMPANY NORTH ANDOVER, MA
DEVICE MODEL	WATTS 3/8 7, 7C AND 3/4 H7,H7C
DEVICE SPECIFICATION	TESTED AND CERTIFIED TO MEET ANSI/ASSE STANDARD 1024 & 1032 CSA CERTIFIED TO STANDARD NO.B64.6
DEVICE PRESSURE	MAXIMUM PRESSURE: 150PSI (10BAR) MINIMUM PRESSURE: 10PSI (69KPA) MAXIMUM RECOMMENDED FLOW: 10GPM
DEVICE TEMPERATURE	WORKING TEMPERATURE: 33F~144F CONSISTENT; INTERMITTENT TO 180F

All models of pedicure spa mentioned above are equipped with the subject device as standard feature, sold and/or shipped to the following states:

- ▶ Effective April 01, 2005:
**ARIZONA, CALIFORNIA, NEBRASKA, NEVADA, OREGON,
TEXAS AND WASHINGTON**
- ▶ Effective June 15, 2005
ILLINOIS, MINNESOTA, WISCONSIN, MICHIGAN
- ▶ Effective May 1, 2007
CONNECTICUT

For additional information, please contact us at 631-243-3336 extension 108.

Very Truly Yours,

Peter Kim
Manager of Technical Support

J&A USA, Inc.
200 Rodeo Drive
Edgewood, NY 11717
Tel: 631-243-3336
Fax: 631-243-3339
www.jausainc.com