

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
2319 DORRIS PLACE
LOS ANGELES, CA 90031

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

PETER KIM
J & A USA, INC.
200 RODEO DRIVE
EDGEWOOD, NY 11717-8317

Telephone: 631-243-3336

Models:

EPISODE (S-TYPE), PETRA, TOEPIA & JULIETTE.

File Number: M-020018

Effective Date: 06/01/2009

Expiration Date: 06/01/2010

Manufacturer: J & A USA, INC.

Item: FOOT SPA

PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.


This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.


CONDITIONS OF APPROVAL:

1. Each water inlet shall be installed a minimum of one inch above the flood level of the foot spa or shall be equipped with spill proof pressure type vacuum breakers approved for both hot and cold water per Section 94.603.4 of LAPC, 2008 Edition.
2. For models with drain pump, discharge shall be routed to an approved indirect waste receptor, 1" or two pipe size, whichever is greater, above its flood level. Gravity drains shall be trapped and vented per Sections 94.1001 & 94.1002 of LAPC, 2008 Edition.
3. This approval is valid for Plumbing only.

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.


Mark K Wang
Mechanical Testing Laboratory, Test Engineer


Mechanical Testing Laboratory